



कार्यालय अधिशासी अभियन्ता, खण्ड कार्यालय, उ०प्र० जल निगम (ग्रामीण), अयोध्या
गाटा सं०-57 मी. माझा जमथरा, (33एमएलडी एस.टी.पी. परिसर के अन्दर), अयोध्या
Email Id: eeupjn_cdfaizabad@yahoo.co.in

पत्राक
सेवा में,

729 / W-5 / 17

दिनांक 20/03/2025

प्रधानाचार्य,
सर्व शिक्षा पब्लिक स्कूल,
परसावन, मिल्कीपुर अयोध्या।

विषय:- जल परीक्षण रिपोर्ट प्रेषित किये जाने के संबंध में।

महोदय,

उपरोक्त विषयक आपके कार्यालय पत्रांक 0 दिनांक 19.03.2024 द्वारा प्राप्त जनपद अयोध्या के सर्व शिक्षा पब्लिक स्कूल, परसावन, मिल्कीपुर से प्राप्त आर०ओ० वॉटर के जल नमूने का रासायनिक परीक्षणोपरान्त जल परीक्षण रिपोर्ट एवं मनी रसीद संख्या..72326.. दिनांक..20/3/25...संलग्न कर प्रेषित है।

संलग्नक- जल परीक्षण रिपोर्ट 1 नग
मनी रसीद सं० ..72326

भवदीय

(अरविन्द यादव)
अधिशासी अभियन्ता



U. P. JAL NIGAM (Rural)

MONEY RECEIPT

72326

Date 20.03.2025

Division

Received from	Cheque No./Cash	Particulars Receipt	Amount	
			Rs.	P.
प्रधानमार्ग सर्व शिक्षा पाठ्यपुस्तक परसला, मिल्कीपुर अगोष्ठा	-119	जल परीक्षण जी.एस.टी.	100	00
			180	00
			1181	00
Account Credited	Account No.		Amount	
	Control	Details	Rs.	P.
Other Income G.S.T.	53500	-	100	00
	13205	-	180	00
रकम सुदर रकम में सुधार मिला			1181	00

For U.P. Jal Nigam (Rural)

Water Analysis Report



District Level Water Analysis Laboratory
Office of the Executive Engineer Khand Karyalay, U.P. Jal Nigam
(Rural) GataN0-57Ml. Manjha Jamthara, (In Campus 33 MLD S.T.P.)

Report No.: UPJN/AYO/MAR/01 Date: 21/03/2025 No. of Pages: 1

Customer Details
Office Name and Address: Sarv Shiksha Public School, Parsawan, Milkipur Ayodhya
Ref. Letter No. & Date: 0 Date:- 19/03/2025

Basic Details of Sample			
District	Ayodhya	Block	Sohawal
Gram Panchayat	Parsawan	Village	Parsawan
Habitation	Parsawan	Location	Parsawan
Water Source	R.o Water	Sample Code	UPJN/AYO/MAR/01
Quantity of Sample	1 Litre	Sampling date	19-03-2025
Sample Received Date	19-03-2025	S. collected by	Karmraj
Sampling Method Used	NA	Sample Depositor	Karmraj
Analysis Start Date	19-03-2025	Analysis Completion date	20-03-2025

S. No.	Analysed Parameters	Observed Value	Specification as per IS 10500:2012(SecondRevision)		Ref. Methods of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8): 2023
2	Total Coliform (CFU/ML)	0	0.0	No relaxation	APHA 24th Edition, 2023
3	pH	7.42	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022, Electrometric Method
4	Colour (Hazen units)	1	5	15	APHA 24rd Edition -2120-Colour Method B (Platinum Cobalt Visual Comparison): 2023
5	Turbidity (NTU)	0.54	1	5	IS 3025 (Part 10):2024 Sec-2 (Nephelometric method)
6	Total Dissolved Solids, mg/l	206	500	2000	IS 3025 (Part 16): 2023 (Gravimetric method)
7	Chloride (as Cl), mg/L	24.99	250	1000	IS 3025 (Part 32): 2019 Argentometric method
8	Total Alkalinity, (as CaCO ₃) mg/l	146	200	600	IS 3025 (Part 23): 2023 (Potentiometric and Indicator method)
9	Total Hardness, (as CaCO ₃) mg/l	132	200	600	IS 3025 (Part 21): 2019 (EDTA method)
10	Calcium (as Ca), mg/l	38	75	200	IS 3025 (Part 40): 2024 EDTA Titrimetric method
11	Sulphate (as SO ₄), mg/l	4.14	200	400	APHA 24rd Edition -4500-SO ₄ Method E (Turbidimetric Method): 2023
12	Nitrate (as NO ₃), mg/l	2.12	45	No relaxation	APHA 24rd Edition -4500- NO ₃ Method B (UV Screening Method): 2023
13	Iron (as Fe), mg/l	0.07	1.0	No relaxation	APHA 24rd Edition -3500-Fe Method B (Phenanthroline Method) : 2023
14	Fluoride (as F), mg/l	0.01	1.0	1.5	APHA 24rd Edition -4500-F Method C (Ion-Selective Electrode Method) : 2023
15	Total Arsenic (as As) mg/l	NA	0.01	No relaxation	APHA 24rd Edition -3500 Method B (Silver Diethyldithiocarbamate Method): 2023
16	Free Residual Chlorine	0	0.2	1	IS-3025(Pt-26):2021
17	Magnesium	26.2	30	100	IS 3025 (Part 46): 2023 (Volumetric method)
18	E. Coll. (Cfu/ml)	0	0.0	No relaxation	APHA 24th Edition, 2023

All These parameters are under NABL Scope, BDL-Below Detection Limit, NA- Not Analysed

- Note:
- This certificate refers only to the particular sample(s) submitted for analysis.
 - This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 - The analysis results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 - Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.
 - Parameters above Permissible Limit are written in bold.
 - Sample(s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available.
 - Sample is not Collected by Lab.

Satish Kumar
SATISH KUMAR
(Report prepared by)

Alok Kumar
ALOK KUMAR
(Report Authorized by)
8881987888
अयोध्या

Laboratory Contact detail: E mail: eeupjn_cdfalzabad@yahoo.co.in

*****END OF THE ANALYSIS REPORT*****

~~PROFORMA FOR~~

Date

Letter


Dated : 20.03.2025

No. UPJN/Ayo/Mar/01

It is certified that an inspection team headed by Mr. Alok Kumar (Chemist) Name of Officer with Designation) From Division Office , U.P. Jal Nigam (RURAL) Ayodhya (Name of Department/ Office) inspected the Sarv Shiksha Public School, Parsawan, Milkipur ,Ayodhya, U.P. -224164 (Name & Address of the School) on 20.03.2025 (Date of Inspection) and on the basis of Water test Report (Attached) bearing No UPJN/Ayo/Mar/01 dated 20.03.2025 of Office of the Executive Engineer Khand Karyalaya U. P. Jal Nigam (Rural), Gata NO-57Mi. Manjha Jamthara, (In Campus 33 MLD S.T.P.) (FHED Lab) certified that the Sarv Shiksha Public School (Name of the School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 Year.

Signature with Seal :


सहायक अभियन्ता
निर्माण खण्ड
उ०प्र० जल निगम (ग्रामीण)
अयोध्या

Name : Ashwini Kumar


Designation : Assistant Engineer

Name & Address of the office / Department:
Division Office , U.P. Jal Nigam (RURAL) Ayodha

To,

Sarv Shiksha Public School,
Parsawan, Milkipur ,Ayodhya, U.P. -224164

(Name & Address of the Instituion)


केमिस्ट
जनपदीय प्रयोगशाखा
उ०प्र०जल निगम (ग्रामीण)
अयोध्या